AOC-1012
8-08

1 of 2

# Commonwealth of Kentucky Court of Justice
## MEETING NOTES

AOC CONSTRUCTION FILE
COUNTY: TODD
FILE CODE: P2
SUBMITTED BY: JB
DATE: 2-18-10

MTG. DATE: 2-12-10

COUNTY: TODD LOCATION:

FACILITY:

AGENDA: SECURITY REVIEW

| Present | Representing | Phone |
|---|---|---|
| | | |
| WILLIAMSON | | |
| HODGES | | |
| | | |
| | | |
| BAUMAN | | |

ITEMS DISCUSSED:

#29

- POLEVATOR - ~~in SPEC~~! 91.0 - 115 vac → 24 vdc XFR.
- E1.1.4 - #22 - DELETE 120V CIRCUIT: 12/2 TO COMM. RM.
  - #23 - RUN ALL CAT5e TO MDF
  - #24 - RUN ALL " " "
  - #25 - " " " " "
  - #35 - (2) 16/2 - NOT (1) ADD (1)
  - #31 - (6) CAT5e → (10) CAT5e ADD (4)
  - #32 - DELETE
- DELETE C'WORK IN [107] - AOC WILL PROVIDE WINSTED SPEC.
  - #33 - (2) 22/15 → (5) 22/15 ADD (1)
  - #34 - DELETE

ACTION ITEMS:

GEN'L. NOTE: MDF IS ON MEZZ. ABOVE 1ST FLR.
IDF IS ON MEZZ. ABOVE 2ND FLR.

DELETE CORRIDOR CARD READER FOR ELEV. 143
- #26 - FIRE WIRE TO F.A. PANEL (ADD) ADD 12/2 TO MDF (2) 18/2 TO MDF
- #27 ADD 16/2 TO MDF, ALSO 18/2 TO MDF

REPORT BY: FILE:

C:

AOC-1012
8-08

# Commonwealth of Kentucky Court of Justice
## MEETING NOTES

MTG. DATE: 2-12-10

COUNTY: TODD

LOCATION:

FACILITY:

AGENDA: SECURITY AUDIT

| Present | Representing | Phone |
|---|---|---|
| | | |
| WILLIAMSON | | |
| HODGES | | |
| | | |
| | | |
| BAUMAN | | |

ITEMS DISCUSSED:

1.2.4 - DELETE CORRIDOR CARD READER ELEV. 143

ACTION ITEMS:

REPORT BY:

FILE:

C: